

Jd 15-5

Jd 15-5

2 1/2" Test Well

6-11-63

# City of Dover Del.

Sandy clay	6'
Spin Sand + Gravel	55'
Brown Clay	60'
Green clay	90'
Green clay with Shell	183'
Coarse Sand Free	189'
Coarse Sand/shell	199'
Good Med. Free Sand.	223'
CLAY	224'
Med Sand.	229'
Clay	335-6"
Free Med Sand.	358'
Good	
Free Med Coarse Sand some clay.	374'
Free Med Coarse Sand - green clay	400'
Tight Sand with clay	421'
Hard Sand - clay	430'
Hard Sand some clay	458'
Clay & Sand	578'

Location  
East Dover  
Elementary School

Static level 50'  
Operating level 78'  
GPM - 46

2 1/2" Steel Casing

211'

2"

339'

Clayton Mark Stramon

Piney Point

369'

Capacity -  
600 GPM

2"

SHANNAN ARTESIAN WELL CO., INC.  
P. O. BOX 217  
ST. MICHAELS, MARYLAND

578'