

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69

WELL COMPLETION REPORT

<p>1. Permit Number: <u>36919</u> Owner of Well: <u>Donald Hoff</u></p>	<p>8. Well Head Completion: Pitless Adapter _____ Type _____ _____ inches above grade</p>
<p>2. Test Well Observation Well _____ Production Well <input checked="" type="checkbox"/> Well Abandoned? Yes _____ No <input checked="" type="checkbox"/></p>	<p>9. Static Water Level: <u>10</u> feet below grade _____ feet above grade</p>
<p>3. Total Well Depth <u>85</u> feet Date Completed <u>8/27/76</u></p>	<p>10. Pumping Water Level: <u>14</u> feet below grade after <u>1</u> hours at <u>60</u> GPM</p>
<p>4. Grout: Type <u>None</u> from _____ feet to _____ feet from _____ feet to _____ feet</p>	<p>11. Permanent Pump Installed? Yes _____ No <input checked="" type="checkbox"/> a. Shallow Well _____ Deep Well _____ b. Reciprocating _____ Rotary _____ Centrifugal _____ Jet _____ Submersible _____ c. Capacity _____ GPM</p>
<p>5. Casing: Type <u>PVC</u> <u>2</u> inches to <u>85</u> feet _____ inches to _____ feet Drive Shoe? Yes _____ No <input checked="" type="checkbox"/></p>	<p>12. Well Number _____ (Leave Blank)</p>
<p>6. Screen Setting: <u>80</u> feet to <u>85</u> feet</p>	
<p>7. Gravel Packed? Yes <input checked="" type="checkbox"/> No _____ <u>80</u> feet to <u>85</u> feet</p>	
<p>13. Well Log</p>	

Formation	Thickness of Stratum	Depth to Bottom of Stratum
OF 24-15		
fine white sand & clay	10'	10'
coarse red gravel	5'	15'
fine white sand	5'	20'
med coarse white sand	20'	40'
coarse white gravel	10'	50'
med white sand	10'	60'
coarse white sand	10'	70'
coarse white gravel	15'	85'