P. O. BOX 188 • BRIDGEVILLE, DELAWARE 19933

Permit #36106

CF 39-C6

Water Well Contractors

CUSTOMER George Briggs JOB 3292

ADDRESS Georgetown, Del. DATE 6/4/76

LOCATION 950' S. E. of farmhouse and 6' E. of lane



FEET FROM GROUND SURFACE 0 TO.....	WELL LOG
0-1	top soil
1-17	fine to med. brown sand
17-23	clay
23-56	fine to coarse tan sand
56-58	iron ore
58-97	fine to coarse tan sand w/gravel
97-110	blue clay

WELL NO. 2	DIAMETER OF WELL 4"	DEPT. OF WELL 96'
HRS. PUMPED 2	SLOT SIZE .030	TYPE OF CASING PVC
CAPACITY G.P.M. 60	DRILLING MACHINE NO. Ingr D-1	LENGTH OF CASING 66'
STATIC LEVEL 9'3" 9.25	DRILLER Ed Kelley	DISTANCE TO TOP OF SCREEN 66-96
PUMPING LEVEL 9'9"	GRAVEL 2	TYPE SCREEN PVC
SPECIFIC CAPACITY 120	BAGS OF CEMENT clay	SIZE OF SCREEN 4"
PUMPED WITH air pumper	DATE WELL COMPLETED 6/4/76	
DEPTH OF CEMENT GROUT 0-56	DRILLER'S HELPER J. Sorl	Ed Kelley
DEPTH GRAVEL PACKED 56-96		WELL DRILLER SIGNATURE