

MAIL TO:
 WATER SUPPLY BRANCH
 DIVISION OF ENVIRONMENTAL CONTROL
 P.O. BOX 140
 DOVER, DELAWARE 19901

STATE OF DELAWARE
 DEPARTMENT OF NATURAL RESOURCES
 AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
 BE RETURNED 21 DAYS AFTER
 CONSTRUCTION DATE

PLEASE PRINT
 PERMIT NO. 0554-04 WELL COMPLETION REPORT

OWNER Sturman, Glenn

CONSTRUCTION DATE 9-26-84
 PURPOSE TEST PERMANENT

- USE DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO
 ABANDONMENT DATE FOR OLD WELL _____
 ABANDONMENT METHOD _____

- DRILLING METHOD
 AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

CASING SEQUENCE

	1st	2nd	3rd	4th
CASING TOP	0			
CASING BOTTOM	10			
CASING DIAMETER	4"			
CASING MATERIAL	VC			

SCREEN SEQUENCE

	1st	2nd	3rd	4th
SCREEN TOP	43			
SCREEN BOTTOM	50			
SCREEN DIAMETER	4"			
SCREEN MATERIAL	VC			

GROUT TYPE CEMENT BENTONITE CLAY
 OTHER _____
 FROM _____ TO _____ FEET
 NON-GROUT BACKFILL OF WELL ANNULUS
 TYPE GRAVEL FROM 0 TO 43 FEET

GRAVEL PACK TYPE 3/32"
 FROM 43 TO 50 FEET
 STATIC WATER LEVEL DATE 9-26-84
 _____ FT. BELOW GROUND SURFACE
 PUMPING WATER LEVEL 19 FT. BELOW GRADE
 AFTER 2 HOURS AT 60 GPM

WELL HEAD COMPLETION:
 TYPE FITLESS ADAPTOR
 OTHER
12 INCHES ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE _____
 RATED CAPACITY (GPM) _____
 PUMP INTAKE SETTING _____ FT. BELOW GRADE

- THE COMPLETED WELL IS?
 A. AT LEAST 5' FROM ANY OVERHANG YES NO
 B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
 C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS (CIRCLE ONE)
 IS 2-50' FROM COMPLETED WELL
 SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS _____

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
top soil very sandy	6	6
light yellow sand		
medium sand	3.5	4
yellow loam to coarse		
fine clean sand	24	28
white sand with gravel	15	44
gravel in coarse sand	42	25
sub-surface sand	2	87
gray clay. Dist	8	75

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF 1 PAGES
 COMPANY NAME White & Neering Corp
 SIGNATURE OF DRILLER IN CHARGE P. Allen White Jr. DATE 10/26/84

DOCUMENT NO. 40-20-70-01-02

WHITE - DRISDC CANARY - CONTRACTOR PINK - OWNER

01/05/10 20-06/78/05/10