

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION

RECEIVED JAN 2 1969

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

WRD-2
11/68

WELL COMPLETION REPORT

1. Permit Number: _____
Well Owner:
Edward J. Webb

2. Test Well
Observation Well _____
Production Well
Well Abandoned? Yes _____ No

3. Well Depth: 80 ft.
Date Completed:
December 3, 68

4. Grout: Type _____
from _____ ft. to _____ ft.
from _____ ft. to _____ ft.

5. Casing: Type _____
2 in. to 76 in. FT
in. to _____ in.
Drive Shoe? Yes _____ No

6. Screen: Slot Size 10
76 ft. to 80 ft.

7. Gravel Packed:
74 ft. to 80 ft.

8. Well Head Completion:
_____ Pitless Adapter
12 inches above grade

9. Static Water Level:
22 1/2 feet below grade

10. Pumping Level:
3 1/2 ft. after 2 hrs.
at 45 GPM

11. Capacity of Permanent Pump:
by others _____ GPM

12. Well Number:
(leave blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
<u>blennies</u>	<u>1</u>	<u>1</u>
<u>light yellow sand</u>	<u>5</u>	<u>6</u>
<u>yellow clay sand</u>	<u>22</u>	<u>28</u>
<u>clean fine yellow sand</u>	<u>19</u>	<u>47</u>
<u>fine yellow sand</u>	<u>5</u>	<u>52</u>
<u>dark yellow clay sand</u>	<u>20</u>	<u>72</u>
<u>yellow + black sand</u>	<u>3</u>	<u>75</u>
<u>dark yellow sand</u>	<u>5</u>	<u>80</u>

Edward J. Webb
RD #2, Box 129
Milton, Del.

14. Signature of Water Well Contractor
R. Allen White
Date December 16, 1968

(over)