

C-5929

DEPARTMENT OF WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19904
 WATER SUPPLY BRANCH

JUN 21 1977

WELL COMPLETION REPORT

1. Permit Number: DE 38810
 Name of Well: BRONXVILLE BRANCH

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No X

3. Total Well Depth 90 feet
 Date Completed 6/15/77

4. Casing: Type STEEL
 from 0 foot to 60 foot
 from foot to foot

5. Casing: Type STEEL
10 inches to 60 feet
10 inches to 50 feet
 Drive Shoe? Yes No X

6. Screen Setting:
60 feet to 90 feet

7. Gravel Packed? Yes X No
1 feet to 90 feet

8. Well Head Completion: FOUNDATION
 Flange Adaptor Type
24 inches above grade

9. Static Water Level:
19 feet below grade
 feet above grade

10. Pumping Water Level:
26 feet below grade after
1 hours at 297 GPM

11. Permanent Pump Installed?
 Yes No X
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

0923-11

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
WHITE SAND + CLAY	13	13
WHITE SAND	8	21
BROWN CLAY	9	30
WHITE SAND + CLAY	20	50
CRACK WHITE SAND	40	90
CLAY	37	127

10/25/78/203/10