

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69

WELL COMPLETION REPORT

WATER RESOURCES

Plot Number: 30904
 Owner of Well: Figueroa
 Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No
 Total Well Depth 52 feet
 Date Completed _____
 Grout: Type none
 from _____ feet to _____ feet
 from _____ feet to _____ feet
 Casing: Type galv. steel
4 inches to 15 feet
2 inches to 46 feet
 Drive Shoe? Yes No
 Screen Setting:
46 feet to 52 feet
 Gravel Packed? Yes No
 _____ feet to _____ feet
 Well Log

8. Well Head Completion:
no Pitless Adapter _____ Type _____
 _____ inches above grade
 9. Static Water Level:
12 feet below grade
22 feet above grade
 10. Pumping Water Level:
 _____ feet below grade after
 _____ hours at _____ GPM
 11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM
 12. Well Number _____
 (Leave Blank)

0954-03

Formation	Thickness of Stratum	Depth to Bottom of Stratum
sand-clay	0	21
sand	21	42
water	42	52
Charles Rosey		
	1-23-75	