

1. Permit Number: 39436
 Owner of Well: C.O. White

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 75 feet
 Date Completed 7-2-75

4. Grout: Type POPC
 from feet to feet
 from feet to feet

5. Casing: Type 2" PVC
0 inches to 75 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
65 feet to 75 feet

7. Gravel Packed? Yes No
65 feet to 75 feet

13. Well Log

8. Well Head Completion:
108 Pitless Adapter Type
8 inches above grade

9. Static Water Level:
12 feet below grade
 feet above grade

10. Pumping Water Level:
20 feet below grade after
2 hours at 50 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

P654-06

| Formation | Thickness of Stratum | Depth to Bottom of Stratum |
|-------------------------|----------------------|----------------------------|
| fine tan sand | 5' | 5' |
| medium brown sand | 5' | 10' |
| medium light brown sand | 20' | 30' |
| fine white sand | 20' | 50' |
| fine light brown sand | 10' | 60' |
| medium brown sand | 15' | 75' |
| | | |
| | | |

14. Signature of Water Well Contractor W. H. Burns Date 7-2-75