

*Rec'd
Lien
6/18/68*

DELMARVA DRILLING CO., INC.

BOX 456, DENTON, MARYLAND - PHONE (301) 479-1678

WELL DRILLING & PUMPS

LAD

PC54-1

DATE May 2, 1968

LOG OF 17" WELL IN 48 INCH HOLE

CUSTOMER Fred O'Neal DRILLER States & Pierson

ADDRESS Seaford, Delaware

LOCATION 200' S. of old well, 30' N. of woods & 2000' E. of farm house

START	STOP	FORMATION
0	5	Berm
5	6	top soil
6	10	fine to med. white & tan sand
10	13	gray clay
13	17	fine white sand
17	24	fine to coarse white sand & some gravel
24	42	fine to coarse white sand & some gravel & stones
42	44	fine to med. white sand w/ some gravel & stones & rock
44	47	gray clay
47	92	fine to med. tan sand
92	104	fine to coarse tan sand
104	105	gray clay

CASING & SCREEN RECORD	
Plain	0 - 40
Screen	40 - 44
Plain	44 - 48
Screen	48 - 52
Plain	52 - 56
Screen	56 - 60
Plain	60 - 64
Screen	64 - 68
Plain	68 - 72
Screen	72 - 76
Plain	76 - 80
Screen	80 - 84
Plain	84 - 88
Screen	88 - 92
Plain	92 - 96
Screen	96 - 100
Plain	
Screen	
Grout	
Clay Seal	
Gravel Pack	

Static Water Level 5 Feet
 G. P. M. Pumped _____
 Water Level While Pumping _____ Feet
 # Bays of Clay Used 5 reg.
 Type Gravel Pack Used grits
 Approx. Gal. Water Used To Drill _____
 Guarantee With Turbine from Test _____ G. P. M.
 Water Appearance (Clear, Clayey, Sandy, Odor, Taste) _____
 Type Casing Kelly Concrete
 Blown or Not no
 Time To Drill 10 hrs.
 Height Berm 5 ft.
 Concrete Block Size & Locations 3x8x12

REMARKS: Replacement well

*68
32*