

MAIL TO:

WATER SUPPLY SECTION  
DIVISION OF WATER RESOURCES  
89 KINGS HIGHWAY  
DOVER, DELAWARE 19901  
PHONE: 302-739-3665  
FAX: 302-739-2296

STATE OF DELAWARE  
DEPARTMENT OF NATURAL RESOURCES  
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST  
BE RETURNED WITHIN 30 DAYS OF  
CONSTRUCTION DATE

FORMATION LOG

Pe 53-15

PAGE 2 OF 3 PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED


PERMIT# 168429-W	LOCAL ID# test for Pe 53-16
------------------	-----------------------------

PROPERTY OWNER JED T. JAMES

WELL CONTRACTOR WHITE DRILLING CORP. LIC# 1

DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
TOP SOIL	0	1
SILTY TAN SAND	1	4
MEDIUM YELLOW SAND	4	21
VERY FINE TO MEDIUM + SOME COARSE WHITE SAND	21	31
VERY FINE TO COARSE WHITE SAND	31	58
VERY FINE TO COARSE YELLOW SAND <sup>color</sup> change	58	63
VERY FINE TO VERY COARSE YELLOW SAND + GRAVEL	63	85
	too shallow for Tbt @ 58'	

OTHER COMMENTS:



HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Signature of Well Driller In Charge: R. Allen White W.D.C. License#: 1 Date: 11/2/99