

STATE OF DELAWARE  
WATER AND AIR RESOURCES COMMISSION

WRD-2  
7/69

Water Resources Division  
Dover, Delaware 19901

PF15-16

WELL COMPLETION REPORT

1. Permit Number: 5-1637  
Owner of Well: Peninsula Court

2. Test Well  
Observation Well   
Production Well   
Well Abandoned? Yes  No

3. Total Well Depth 74 feet  
Date Completed 4-10-75

4. Grout: Type NONE  
from      feet to      feet  
from      feet to      feet

5. Casing: Type 2" PVC  
0 inches to 74 feet  
     inches to      feet  
Drive Shoe? Yes  No

6. Screen Setting:  
69 feet to 74 feet

7. Gravel Packed? Yes  No   
69 feet to 74 feet

8. Well Head Completion:  
4 Pitless Adapter Ball Type  
     inches above grade

9. Static Water Level:  
13 feet below grade  
     feet above grade

10. Pumping Water Level:  
20 feet below grade after  
2 hours at 60 GPM

11. Permanent Pump Installed?  
Yes  No   
a. Shallow Well   
    Deep Well   
b. Reciprocating  Rotary   
    Centrifugal  Jet   
    Submersible   
c. Capacity      GPM

12. Well Number       
(Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
clay	15'	15'
medium yellow sand	15'	30'
" red "	10'	40'
" white "	25'	65'
coarse red "	4'	69'
" yellow "	5'	74'