

MAIL TO:

WATER SUPPLY BRANCH
 DIVISION OF ENVIRONMENTAL CONTROL
 P.O. BOX 1401
 DOVER, DELAWARE 19903

**STATE OF DELAWARE
 DEPARTMENT OF NATURAL RESOURCES
 AND ENVIRONMENTAL CONTROL**

WELL COMPLETION REPORT MUST
 BE RETURNED 30 DAYS AFTER
 CONSTRUCTION DATE

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 80076E LOCAL ID _____

OWNER Allan Stoeckel

CONSTRUCTION DATE 9-7-89

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL Completion

ABANDONMENT METHOD Element New well

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 32

CASING SEQUENCE

	INNER	OUTER
CASING TOP	12"	
CASING BOTTOM	27	
CASING DIAMETER	4"	
CASING MATERIAL	PVC	

SCREEN SEQUENCE

	INNER	OUTER
SCREEN TOP	27	
SCREEN BOTTOM	32	
SCREEN DIAMETER	4"	
SCREEN MATERIAL	PVC	

WRITTEN APPROVAL FOR SCREENING/
 GRAVEL PACKING MORE THAN ONE AQUIFER
 MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT BENTONITE CLAY

OTHER: _____

FROM 0 TO 20 FEET

NON-GROUT BACKFILL OF WELL ANNULUS

TYPE native FROM 20 TO 25 FEET

GRAVEL PACK: TYPE 3/32"

FROM 25 TO 32 FEET

STATIC WATER LEVEL: DATE 9-7-89

6 FT. (Below) (above) GROUND SURFACE

PUMPING WATER LEVEL: 15 FT. BELOW GRADE

AFTER 2 HOURS AT 70 GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR

OTHER _____
12 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE _____

RATED CAPACITY (GPM) _____


PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

	YES	NO
A. AT LEAST 15' FROM ANY FOUNDATION	<input checked="" type="checkbox"/>	<input type="checkbox"/>
B. AT LEAST 50' FROM ANY SEPTIC TANK	<input checked="" type="checkbox"/>	<input type="checkbox"/>
C. AT LEAST 10' FROM TOWN SEWER LINE	<input checked="" type="checkbox"/>	<input type="checkbox"/>
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD	<input checked="" type="checkbox"/>	<input type="checkbox"/>

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC, TILE FIELD, CESSPOOL OR PRIVY
 IS 100' FROM COMPLETED WELL.
 IS COMPLETED WELL LOCATED AS SHOWN
 ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



Pf23-05

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
TOP SOIL	0	1
FINE TO COARSE		
YELLOW SAND	1	13
FINE TO COARSE		
WHITE SAND	13	24
FINE TO COARSE		
YELLOW SAND	24'	32'

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF 1 PAGES
 COMPANY NAME White Drilling Corp.
 SIGNATURE OF DRILLER IN CHARGE: R. Allen White DATE 9-9-89