

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 105504 LOCAL ID \_\_\_\_\_

OWNER Charles P. Spicer

CONSTRUCTION DATE Jan 29, 1996

PURPOSE:  TEST  PERMANENT

USE:  DOMESTIC  AGRICULTURAL  
 COMMERCIAL  INDUSTRIAL  
 IRRIGATION  PUBLIC  
 OBSERVATION  DEWATERING  
 HEAT PUMP RECHARGE  HEAT PUMP SUPPLY

IS THIS A REPLACEMENT WELL? YES  NO

ABANDONMENT DATE FOR OLD WELL \_\_\_\_\_

ABANDONMENT METHOD \_\_\_\_\_

DRILLING METHOD

AUGERED  BORED  CABLE TOOL  
 DRIVEN  JETTED  AIR ROTARY  
 MUD ROTARY  REVERSE  WASHED  
 OTHER (Specify) \_\_\_\_\_

TOTAL DEPTH DRILLED 40'

CASING SEQUENCE

	INNER	OUTER
CASING TOP	<u>12" above</u>	
CASING BOTTOM	<u>32'</u>	
CASING DIAMETER	<u>4"</u>	
CASING MATERIAL	<u>PVC</u>	

SCREEN SEQUENCE

	INNER	OUTER
SCREEN TOP	<u>32'</u>	
SCREEN BOTTOM	<u>40'</u>	
SCREEN DIAMETER	<u>4"</u>	
SCREEN MATERIAL	<u>PVC</u>	

WRITTEN APPROVAL FOR SCREENING/  
 GRAVEL PACKING MORE THAN ONE AQUI-  
 FER MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT  BENTONITE CLAY

OTHER: \_\_\_\_\_

FROM 0 TO 20 FEET

NON-GROUT, BACKFILL OF WELL ANNULUS  
 TYPE Native FROM 20 TO 26 FEET

GRAVEL PACK: TYPE #1 Ricci

FROM 26 TO 40 FEET

STATIC WATER LEVEL: DATE Jan 29, 1996

7 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 16 FT. BELOW GRADE

AFTER 2 HOURS AT 50 GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR

OTHER  \_\_\_\_\_  
12 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE STA-Rite

RATED CAPACITY (GPM) 25

PUMP INTAKE SETTING 30' FT. BELOW GRADE

THE COMPLETED WELL IS?


YES NO  
 A. AT LEAST 15' FROM ANY FOUNDATION    
 B. AT LEAST 50' FROM ANY SEPTIC TANK    
 C. AT LEAST 10' FROM TOWN SEWER LINE    
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY  
 IS 50' FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN  
 ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



PS 33-05

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
<u>Top soil</u>	<u>0</u>	<u>1</u>
<u>dirty tan sand and clay</u>	<u>1</u>	<u>11</u>
<u>fine to coarse white sand</u>	<u>11</u>	<u>40</u>

SUPPLEMENTAL DRILLERS LOG ATTACHED YES  NO

PAGE 1 OF 1 PAGES

COMPANY NAME White Drilling Coy.

SIGNATURE OF DRILLER IN CHARGE: David W. White DME  
Feb 27, 1996