

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69
 WATER SUPPL

MAY 5

WELL COMPLETION REPORT

1. Permit Number: 37953
 Owner of Well: Nantuxlo Homes
David J. Moore

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 93 feet
 Date Completed 4-24-77

4. Grout: Type None
 from _____ feet to _____ feet
 from _____ feet to _____ feet

5. Casing: Type 2" PVC
0 inches to 93 feet
 _____ inches to _____ feet
 Drive Shoe? Yes No

6. Screen Setting:
88 feet to 93 feet

7. Gravel Packed? Yes No
88 feet to 93 feet

8. Well Head Completion:
yes Pitless Adapter Baker Type _____
 _____ inches above grade

9. Static Water Level:
 _____ feet below grade
 _____ feet above grade

10. Pumping Water Level:
 _____ feet below grade after
 _____ hours at _____ GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number _____
 (Leave Blank)

PS 41-07

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
yellow clay	5'	5'
fine white sand	5'	10'
fine white sand and clay	5'	15'
yellow clay	5'	20'
medium white sand	10'	30'
coarse yellow sand	20'	50'
medium white "	10'	60'
coarse yellow "	10'	80'
" gravel	13'	93'