

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2/
 7/69

WATER SUPPLY BR

WELL COMPLETION REPORT

MAY 19 1977

1. Permit Number: 36442
 Owner of Well: John F. Clark

8. Well Head Completion: yes
 Pitless Adapter None Type _____
 _____ inches above grade

2. Test Well _____
 Observation Well _____
 Production Well
 Well Abandoned? Yes _____ No

9. Static Water Level: _____
 _____ feet below grade
 _____ feet above grade

3. Total Well Depth 83 feet
 Date Completed 5-17-77

10. Pumping Water Level: _____
13 feet below grade after
2 hours at 60 GPM

4. Grout: Type NONE
 from _____ feet to _____ feet
 from _____ feet to _____ feet

11. Permanent Pump Installed?
 Yes No _____
 a. Shallow Well
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity 10 GPM

5. Casing: Type 4" PVC
0 inches to 83 feet
 _____ inches to _____ feet
 Drive Shoe? Yes _____ No

12. Well Number _____
 (Leave Blank)

6. Screen Setting:
78 feet to 83 feet

7. Gravel Packed? Yes No _____
78 feet to 83 feet

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Formation PF 42-09		
fine white sand	5'	5'
medium coarse white sand	10'	15'
fine yellow sand	10'	25'
medium coarse brown sand	10'	35'
" " yellow "	15'	50'
coarse brown sand	10'	60'
medium coarse yellow sand	10'	70'
" " " "	10'	82'