

1. Permit Number: 36021  
 Owner of Well: Eldridge J. O'Neal

2. Test Well  
 Observation Well   
 Production Well   
 Well Abandoned? Yes  No

3. Total Well Depth 65 feet  
 Date Completed 5-13-76

4. Grout: Type NONE  
 from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 from \_\_\_\_\_ feet to \_\_\_\_\_ feet

5. Casing: Type 2" PVC  
 \_\_\_\_\_ inches to 65 feet  
 \_\_\_\_\_ inches to \_\_\_\_\_ feet  
 Drive Shoe? Yes  No

6. Screen Setting:  
60 feet to 65 feet

7. Gravel Packed? Yes  No   
60 feet to 65 feet

8. Well Head Completion:  
 No Pitless Adapter \_\_\_\_\_ Type \_\_\_\_\_  
8 inches above grade

9. Static Water Level:  
7 feet below grade  
 \_\_\_\_\_ feet above grade

10. Pumping Water Level:  
15 feet below grade after  
3 hours at 20 GPM

11. Permanent Pump Installed?  
 Yes  No   
 a. Shallow Well \_\_\_\_\_  
 Deep Well \_\_\_\_\_  
 b. Reciprocating \_\_\_\_\_ Rotary \_\_\_\_\_  
 Centrifugal \_\_\_\_\_ Jet \_\_\_\_\_  
 Submersible \_\_\_\_\_  
 c. Capacity \_\_\_\_\_ GPM

12. Well Number \_\_\_\_\_  
 (Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
<u>Formation PF 43-03</u>		
<u>fine yellow sand</u>	<u>10'</u>	<u>10'</u>
<u>fine white sand</u>	<u>10'</u>	<u>20'</u>
<u>medium coarse brown sand</u>	<u>10'</u>	<u>30'</u>
<u>red gravel</u>	<u>10'</u>	<u>40'</u>
<u>medium coarse yellow sand</u>	<u>10'</u>	<u>50'</u>
<u>coarse white sand</u>	<u>15'</u>	<u>65'</u>

RECEIVED  
 MAY 17 1976

14. Signature of Water Well Contractor W. H. Burns Date May 14 1976 WATER RESOURCES SECTION