

JUN 29 1976

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

WD-2
7/69

PF 74-12

STATE OF DELAWARE
WATER RESOURCES SECTION

WELL COMPLETION REPORT

1. Permit Number: 36090
Owner of Well: Joseph Smith

8. Well Head Completion:
No Pitless Adapter _____ Type _____
_____ inches above grade

2. Test Well
Observation Well _____
Production Well
Well Abandoned? Yes _____ No _____

9. Static Water Level:
11 feet below grade
_____ feet above grade

3. Total Well Depth 41 feet
Date Completed 6-7-76

10. Pumping Water Level:
19 feet below grade after
1 hour at 75 GPM

4. Grout: Type Cement
from 3 feet to 15 feet
from _____ feet to _____ feet

11. Permanent Pump Installed? Yes _____ No
a. Shallow Well _____
Deep Well _____
b. Reciprocating _____ Rotary _____
Centrifugal _____ Jet _____
Submersible _____
c. Capacity _____ GPM

5. Casing: Type PVC
0 inches to 36 feet
_____ inches to _____ feet
Drive Shoe? Yes _____ No

12. Well Number _____
(Leave Blank)

6. Screen setting:
36 feet to 41 feet

7. Gravel Packed? Yes No _____
34 feet to 41 feet

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
<u>yellow sand</u>	<u>0</u>	<u>5</u>
<u>brn sandy clay</u>	<u>5</u>	<u>8</u>
<u>brn sand - med</u>	<u>8</u>	<u>15</u>
<u>dk brn sand - med</u>	<u>15</u>	<u>25</u>
<u>lt tan sand - med</u>	<u>25</u>	<u>36</u>
<u>brn sand - med</u>	<u>36</u>	<u>41</u>