

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69

WELL COMPLETION REPORT

PFSS-17

1. Permit Number: 36238
 Owner of Well: Megac P&H

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 125 feet
 Date Completed 6-8-76

4. Grout: Type NONE
 from feet to feet
 from feet to feet

5. Casing: Type 2" PVC
0 inches to 12.5 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
115 feet to 125 feet

7. Gravel Packed? Yes No
115 feet to 125 feet

8. Well Head Completion:
 Yes Pitless Adapter Paper Type
 inches above grade

9. Static Water Level:
6 feet below grade
 feet above grade

10. Pumping Water Level:
10 feet below grade after
2 hours at 25 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
fine brown sand	10'	10'
medium coarse brown sand	10'	20'
fine yellow sand	10'	30'
blue clay	60'	90'
coarse gray sand & gravel	10'	100'
fine gray sand	10'	110'
coarse light brown sand & gravel	15'	125'