MAIL TO:

STATE OF DELAWARE DEPARTMENT OF NATURAL RESOURCES L AND ENVIRONMENTAL CONTROL

WATER SUPPLY BRANCH DIVISION OF ENVIRONMENTAL CONTROL P.O. BOX 1401

DOVER, DELAWARE 19903

WELL COMPLETION REPORT

WELL COMPLETION REPORT MUST BE RETURNED 30 DAYS AFTER CONSTRUCTION DATE;

PLEASE PRINT WELL COMPLE	ETION REPORT
PERMIT NO. 28835 LOCAL ID	TYPE OF PERMANENT PUMP INSTALLED:
OWNER BLUE HERON EST. Walt. Co.	PUMP MANUFACTURE
	RATED CAPACITY (GPM)
CONSTRUCTION DATE OCT. 25, 1991	PUMP INTAKE SETTING FT. BELOW GRADE
PURPOSE: TEST TEST TEST TEST	THE COMPLETED WELL IS?
USE: DOMESTIC DAGRICULTURAL	YES NO A. AT LEAST 15' FROM ANY FOUNDATION
□ COMMERCIAL □ INDUSTRIAL	A. AT LEAST 15' FROM ANY FOUNDATION B. AT LEAST 50' FROM ANY SEPTIC TANK D
☐ IRRIGATION	C. AT LEAST 30 FROM TOWN SEWER LINE
© OBSERVATION DEWATERING	D. AT LEAST 100 FROM THE NEAREST EDGE
☐ HEAT PUMP RECHARGE ☐ HEAT PUMP SUPPLY	OF ANY TILE FIELD
☐ OTHER (Specify)	THE NEAREST NEIGHBORS (CIRCLE ONE)
IS THIS A REPLACEMENT WELL? YES □ NO 🕰—	SEPTIC TILE FIELD CESSPOOL OR PRIVY
ABANDONMENT DATE FOR OLD WELL	IS 780 FROM COMPLETED WELL.
ABANDONMENT METHOD	IS COMPLETED WELL LOCATED AS SHOWN
	ON APPLICATION FORM?
DRILLING METHOD	IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.
☐ AUGERED ☐ BORED ☐ CABLE TOOL ☐ DRIVEN ☐ JETTED ☐ AIR ROTARY	
☐ DAIVEN ☐ JETTED ☐ AIR NOTARY ☐ REVERSE ☐ WASHED	,
OTHER (Specify)	
TOTAL DEPTH DRILLED 70	
,	
CASING SEQUENCE	.,
INNER OUTER	5 0 99J
CASING TOP /2	- 51
CASING BOTTOM 40'	·
CASING MATERIAL SCREEN SEQUENCE	
INNER OUTER	
SCREEN TOP 60 -	
SCREEN BOTTOM 70	DRILLERS LOG DESCRIPTION TOP OF STRATA BOTTOM OF STRATA
SCREEN DIAMETER 4//2" SCREEN MATERIAL PIC.	TOP SOIL 0 1
SCREEN MATERIAL WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE AGU-	
GRAVEL PACKING MORE THAN ONE AQU-	
GROUT TYPE: CEMENT [] BENTONITE CLAY [2]-	FINE WHITE SAND 13 24
OTHER:	FINE-LUMPSE TANSAND 24 36
FROM FEET	FINE-COARSE ORANGE SAND 36 55
NON-GROUT BACKFILL OF WELL ANNULUS TYPE FROM TO FEET	FINE THEOLUM YELLOWSOND 55 101
GRAVEL PACK: TYPE MORIE T.Z.	
FROM	VERY FINE TO COMPOSE
STATIC WATER LEVEL: DATE 0 67.25-1991	CRANCE SAND 61 71
FT. (Below, above) GROUND SURFACE	
PUMPING WATER LEVEL: FT. BELOW GRADE	
AFTER HOURS AT GPM.	
WELL HEAD COMPLETION:	SUPPLEMENTAL DRILLERS LOG ATTACHED YES D NO EL
TYPE: PITLESS ADAPTOR (4-	PAGE 1 OF PAGES A.A.
OTHER □	COMPANY NAME IN KILL Dulling Corp.
12 INCHES ABOVE GRADE.	SIGNATURE OF DRILLER IN CHARGE: DATE
	R. allen Whate Nov. 26,1991
1	