

**A.C. SCHULTES OF DELAWARE, INC.**  
 P.O. BOX 188 - BRIDGEVILLE, DE 19933

PHONE: 302-337-4777  
 FAX: 302-337-8234

**DRILLER'S LOG**

**CUSTOMER:** STOCKLEY MEDICAL CENTER **JOB #:** 4659  
 % DAVIS, BOWEN & FRIEDEL, INC  
**ADDRESS:** P. O. BOX 93; SALISBURY, MD 21803-0093 **DATE:** 8/22/20  
**LOCATION:** STOCKLEY CENTER, PATRIOT'S WAY, GEORGETOWN, DE

GROUND	2'	FT FROM GROUND	
		SURFACE 0 TO .....	WELL LOG
T O T A L  D E P T H	212'	0-1'	TOPSOIL
		1-23'	COARSE ORANGE SAND & STONE
		23-39'	GRAY & ORANGE CLAY
		39-94'	MED-COARSE ORANGE SAND
		94-128'	FINE SAND & CLAY
		128-139'	FINE GRAY SAND
		139-150'	FINE SILTY GRAY SAND
		150-172'	MED GRAY SAND
		172-176'	MED GRAY SILTY SAND
		176-197'	MED GRAY SAND WSILT
		197-211'	FINE SILTY SAND
		211-238'	COARSE GRAY SAND
		238-255'	FINE SILTY GRAY SAND
		255-280'	FINE SILTY SAND & CLAY

<b>WELL NO:</b>	TW#1	<b>PUMPED WITH:</b>	SUB TEST PUMP	<b>SLOT SIZE:</b>	.030
<b>WELL DIAMETER:</b>	4"	<b>CASING DIAMETER:</b>	4"	<b>SCREEN DIAMETER:</b>	4"
<b>WELL DEPTH:</b>	237'	<b>CASING TYPE:</b>	PVC	<b>SCREEN TYPE:</b>	PVC
<b>STATIC LEVEL:</b>	14.70'	<b>CASING DEPTH:</b>	212'	<b>SCREEN LENGTH:</b>	25'
<b>PUMPING LEVEL:</b>	54.45'	<b>GROUT TYPE:</b>	CLAY	<b>GRAVEL SIZE:</b>	#2
<b>TEST CAPACITY:</b>	112.9	<b>GROUT DEPTH:</b>	0-200'	<b>GRAVEL DEPTH:</b>	200-260'
<b>SPEC. CAPACITY:</b>	2.84	<b>GROUT AMOUNT:</b>	12 BAGS	<b>GRAVEL AMOUNT:</b>	25 BAGS
<b>HRS PUMPED:</b>	24	<b>DRILLING RIG:</b>	D-6		

**PERMIT #:** 215494 **FOREMAN:** G. DeCARLO **HELPER:** B. BOWDEN/P. MONCEAUX

**AUTHORIZATION #:** 4514380