


4387

STATE OF DELAWARE  
 WATER AND AIR RESOURCES COMMISSION  
 Water Resources Division  
 Dover, Delaware 19901



WELL COMPLETION REPORT

1. Permit Number: WB-6-144/1973  
 Owner of Well: Richard C. Johnson

2. Test Well  
 Observation Well   
 Production Well   
 Well Abandoned? Yes  No

3. Total Well Depth 65' feet  
 Date Completed 3/1/73

4. Grout: Type Cement  
 from 0 feet to 15 feet  
 from      feet to      feet

5. Casing: Type PVC  
2" inches to 55' feet  
     inches to      feet  
 Drive Shoe? Yes  No

6. Screen Setting:  
55 feet to 65 feet

7. Gravel Packed? Yes  No   
50 feet to 65 feet

8. Well Head Completion:  
 Pickups 15' Type F  
15 inches above grade

9. Static Water Level:  
12 feet below grade  
     feet above grade

10. Pumping Water Level:  
22 feet below grade after  
1 1/2 hours at 40 GPM

11. Permanent Pump Installed?  
 Yes  No   
 a. Shallow Well   
    Deep Well   
 b. Reciprocating  Rotary   
    Centrifugal  Jet   
    Submersible   
 c. Capacity      GPM

12. Well Number       
 (Leave Blank)

Pg 44-14

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
top soil	0	1
med. white sand	1	7
med. coarse tan sand	7	21
fine-med tan sand	21	30
med - coarse tan sand, white clay	30	47
med - coarse tan sand	47	66
med - coarse tan sand / fine med	66	71

14. Signature of Water Well Contractor Edna Mae Dunning Date March 13, 1973

(over)