

1. Permit Number: 34749
 Owner of Well: Enchil Properties
 2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 172 feet
 Date Completed 8-22-88

4. Grout: Type DDGE
 from feet to feet
 from feet to feet

5. Casing: Type 2" PVC
0 inches to 72 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting: 67 feet to 172 feet

7. Gravel Packed? Yes No
67 feet to 172 feet

8. Well Head Completion: Yes Pitless Adapter: Saker Type
 inches above grade

9. Static Water Level: 6 feet below grade
 feet above grade

10. Pumping Water Level: 13 feet below grade after 33 hours at 33 GPM

11. Permanent Pump Installed? Yes No
 a. Shallow Well Deep Well
 b. Reciprocating Centrifugal Rotary Jet
 Submersible
 c. Capacity 10 GPM
 12. Well Number
 (Leave Blank)

13. Well Log	Formation	Thickness of Stratum	Depth to Bottom of Stratum
<u>fine yellow sand</u>		<u>10'</u>	<u>10'</u>
<u>" white "</u>		<u>10'</u>	<u>20'</u>
<u>Coarse "</u>		<u>10'</u>	<u>30'</u>
<u>fine yellow "</u>		<u>10'</u>	<u>40'</u>
<u>Coarse white sand</u>		<u>25'</u>	<u>65'</u>
<u>" brown "</u>		<u>17'</u>	<u>72'</u>

14. Signature of Water Well Contractor W. H. Burns Date 8-25-88