

PN 54-70

Permit Number: 38917
Owner of Well: Francis Meyer

Test Well
Observation Well
Production Well
Well Abandoned? Yes No

Total Well Depth 88 feet
Date Completed 8-14-77

Grout: Type None
from feet to feet
from feet to feet

Casing: Type 2" PVC
0 inches to 88 feet
 inches to feet

Drive Shoe? Yes No

Screen Setting: 83 feet to 88 feet

Gravel Packed? Yes No
83 feet to 88 feet

8. Well Head Completion:
AD Pitless Adapter
8 inches above grade
Type

9. Static Water Level:
12 feet below grade
 feet above grade

10. Pumping Water Level:
16 feet below grade after
2 hours at GPM

11. Permanent Pump Installed?
Yes No
a. Shallow Well
 Deep Well
b. Reciprocating Rotary
 Centrifugal Jet
c. Capacity GPM

12. Well Number
(Leave Blank)

Formation	Thickness of Stratum	Depth to Bottom of Stratum
<u>white clay</u>	<u>5'</u>	<u>5'</u>
<u>medium brown sand</u>	<u>5'</u>	<u>10'</u>
<u>" white "</u>	<u>10'</u>	<u>20'</u>
<u>fine "</u>	<u>10'</u>	<u>30'</u>
<u>medium "</u>	<u>20'</u>	<u>56'</u>
<u>sand "</u>	<u>20'</u>	<u>70'</u>
<u>" brown "</u>	<u>18'</u>	<u>88'</u>

Nature of Water Well Contractor Lawrence
Date 7-14-77