MAIL TO:
WATER SUPPLY BRANCH
DIVISION OF ENVIRONMENTAL CONTROL
P.O. BOX 1401
DOVER, DELAWARE 19901

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST BE RETURNED 21 DAYS AFTER CONSTRUCTION DATE

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 61991 LOCAL ID H-5

OWNER University of Del.

CONSTRUCTION DATE 8/1/85

PURPOSE: ☒ TEST ☐ PERMANENT

USE: ☐ DOMESTIC ☐ AGRICULTURAL
☐ COMMERCIAL ☐ INDUSTRIAL
☐ IRRIGATION ☐ PUBLIC
☒ MONITOR ☐ DEWATERING
☐ HEAT PUMP RECHARGE ☐ HEAT PUMP SUPPLY
☐ OTHER (Specify)

IS THIS A REPLACEMENT WELL? YES ☐ NO ☒

ABANDONMENT DATE FOR OLD WELL N/A

ABANDONMENT METHOD

DRILLING METHOD

☒ AUGERED ☐ BORED ☐ CABLE TOOL
☐ DRIVEN ☐ JETTED ☐ AIR ROTARY
☐ MUD ROTARY ☐ REVERSE ☐ WASHED
☐ OTHER (Specify)

TOTAL DEPTH DRILLED 20'

CASING SEQUENCE

	1st	2nd	3rd	4th
CASING TOP	+6"			
CASING BOTTOM	12.5'			
CASING DIAMETER	1.25"			
CASING MATERIAL	PVC			

SCREEN SEQUENCE

	1st	2nd	3rd	4th
SCREEN TOP	12.5'			
SCREEN BOTTOM	15.0'			
SCREEN DIAMETER	1.25"			
SCREEN MATERIAL	PVC			

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE AQUIFER MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT ☐ BENTONITE CLAY ☒
OTHER:
FROM 0 TO 7 FEET
NON-GROUT BACKFILL OF WELL ANNULUS
TYPE FROM N/A TO FEET
GRAVEL PACK: TYPE
FROM TO FEET
STATIC WATER LEVEL: DATE 8/1/85
+ FT. (Below, ~~above~~) GROUND SURFACE
PUMPING WATER LEVEL: FT. BELOW GRADE
AFTER HOURS AT GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR ☐
OTHER ☒ PVC CAP
6 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE N/A
RATED CAPACITY (GPM)
PUMP INTAKE SETTING FT. BELOW GRADE

THE COMPLETED WELL IS?

	YES	NO
A. AT LEAST 5' FROM ANY OVERHANG	☒	☐
B. AT LEAST 50' FROM ANY SEPTIC TANK	☐	☐
C. AT LEAST 10' FROM TOWN SEWER LINE	☒	☐
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD	☐	☐

N/A

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY
IS FROM COMPLETED WELL.
IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM? ☒ ☐
IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

Ph35-09
12

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
TOPSOIL	0	0.7
ORANGE M SAND W/ TR. GRAVEL & CLAY	0.7	10.0
WHITE F-M SAND W/ TR. SILT	10.0	19.5

SUPPLEMENTAL DRILLERS LOG ATTACHED YES ☐ NO ☒
PAGE 1 OF PAGES
COMPANY NAME D&S
SIGNATURE OF DRILLER IN CHARGE: DATE 8/6/85

DOCUMENT NO. 40-08-78-01-03

WHITE - DNREC CANARY - CONTRACTOR PINK - OWNER