



STATE OF DELAWARE  
WATER AND AIR RESOURCES COMMISSION  
Water Resources Division  
Dover, Delaware 19901

STATE OF DELAWARE  
WATER RESOURCES SECTION

WELL COMPLETION REPORT

1. Permit Number: 35463  
Owner of Well: A. S. Steward  
3. Well Head Completion: Footless Adapter Baker Type \_\_\_\_\_ inches above grade

2. Test Well  
Observation Well \_\_\_\_\_  
Production Well ✓  
Well Abandoned? Yes \_\_\_\_\_ No ✓

3. Total Well Depth 61' feet  
Date Completed 1-28-76

4. Grout: Type None  
from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
from \_\_\_\_\_ feet to \_\_\_\_\_ feet

5. Casing: Type 4" PVC  
inches to 61 feet  
inches to \_\_\_\_\_ feet  
Drive Shoe? Yes \_\_\_\_\_ No ✓

6. Screen Setting:  
56 feet to 61 feet

7. Gravel Packed? Yes ✓ No \_\_\_\_\_  
56 feet to 61 feet

13. Well Log	Formation	Thickness of Stratum	Depth to Bottom of Stratum
<u>medium fine white sand</u>		<u>30'</u>	<u>30'</u>
<u>fine white sand</u>		<u>10'</u>	<u>46'</u>
<u>medium fine brown sand</u>		<u>10'</u>	<u>56'</u>
<u>medium brown sand</u>		<u>5'</u>	<u>55'</u>
<u>coarse brown sand</u>		<u>6'</u>	<u>61'</u>

9. Static Water Level:  
9 feet below grade  
\_\_\_\_\_ feet above grade

10. Pumping Water Level:  
15 feet below grade after  
2 hours at 55 GPM

11. Permanent Pump Installed?  
Yes ✓ No \_\_\_\_\_  
a. Shallow Well ✓ Deep Well \_\_\_\_\_  
b. Reciprocating \_\_\_\_\_ Rotary \_\_\_\_\_  
Centrifugal \_\_\_\_\_ Jet \_\_\_\_\_  
Submersible \_\_\_\_\_  
c. Capacity 10 GPM \_\_\_\_\_

12. Well Number \_\_\_\_\_  
(Leave Blank)

14. Signature of Water Well Contractor W. H. Burns Date 1-30-76

ph 53-09  
WRD-2  
7/69