



WRD-2
7/68

STATE OF DELAWARE
RECEIVED JAN 19 1969

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

Pi 13-1

WELL COMPLETION REPORT

James Travis

1. Permit Number: _____

11. Well Log

2. Well Depth 70 ft.
Date Completed 12-10-68

3. Grout: Type _____
from _____ ft. to _____ ft.

4. Casing:
3 in. to 50 ft.
_____ in. to _____ ft.
Drive shoe? Yes _____ No X

5. Screen:
50 ft. to 70 ft.

6. Well Head Completion:
_____ Pitless Adapter
_____ inches above grade

7. Static Water Level:
9 feet below grade

8. Pumping Level:
25 ft. after 2 hrs.
at 60 GPM

9. Type of Permanent Pump:
Reciprocating _____ Jet _____
Submersible _____ Other _____
Capacity: _____ GPM

10. If well was electric or gamma logged submit copies of the log with this report.

Formation	Thickness of Stratum	Depth to bottom of Stratum
top soil	0-1	
tan sand w/ clay	1-5	
fine-coarse tan sand	5-14	
tan sand w/ gravel	14-26	
fine-coarse tan sand	26-28	
tan sand w/ gray clay	28-38	
tan sand w/ gravel	38-70	
tan sand w/ gravel & multi clays	70-78	
gray clay	78-80	

12. Well Number _____
(leave blank)

13. Signature of Water Well Contractor
Delmarva Drilling Co., Inc.

Date 12-18-68

(over)