

WELL COMPLETION REPORT

P123-03

PLEASE PRINT

PERMIT NO. 108638 LOCAL ID _____

OWNER Robert W. Tunwell, Jr.

CONSTRUCTION DATE 6/25/96

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 OBSERVATION DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL 6/25/96

ABANDONMENT METHOD ben

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 52'

CASING SEQUENCE

	INNER	OUTER
CASING TOP	<u>41'</u>	
CASING BOTTOM	<u>42'</u>	
CASING DIAMETER	<u>4"</u>	
CASING MATERIAL	<u>PVC</u>	

SCREEN SEQUENCE

	INNER	OUTER
SCREEN TOP	<u>42'</u>	
SCREEN BOTTOM	<u>52'</u>	
SCREEN DIAMETER	<u>4"</u>	
SCREEN MATERIAL	<u>PVC</u>	

WRITTEN APPROVAL FOR SCREENING/
 GRAVEL PACKING MORE THAN ONE AQUI-
 FER MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT BENTONITE CLAY

OTHER: N/A

FROM 0 TO 30 FEET

NON-GROUT BACKFILL OF WELL ANNULUS
 TYPE _____ FROM _____ TO _____ FEET

GRAVEL PACK: TYPE morie blend 1 & 2

FROM 33 TO 52 FEET

STATIC WATER LEVEL: DATE 6/25/96
18 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 26 FT. BELOW GRADE
 AFTER _____ HOURS AT 30 GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR

OTHER _____
 _____ INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE _____
 RATED CAPACITY (GPM) N/A

PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?


	YES	NO
A. AT LEAST 15' FROM ANY FOUNDATION	<input checked="" type="checkbox"/>	<input type="checkbox"/>
B. AT LEAST 50' FROM ANY SEPTIC TANK	<input checked="" type="checkbox"/>	<input type="checkbox"/>
C. AT LEAST 10' FROM TOWN SEWER LINE	<input checked="" type="checkbox"/>	<input type="checkbox"/>
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD	<input checked="" type="checkbox"/>	<input type="checkbox"/>

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS 100' FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN
 ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0	1
Fine Brown sand	1	7
Brown clay	7	11
Coarse Brown sand	11	21
Coarse tan sand	21	52

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF 1 PAGES

COMPANY NAME Atlantic Well Drilling
 SIGNATURE OF DRILLER IN CHARGE: Edward J. Pully DATE _____