

RECEIVED
MAY 12 1976

STATE OF DELAWARE
WATER RESOURCES SECTION

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

WELL COMPLETION REPORT

RECEIVED
WRD-2
7/69

MAY 14 1976

DELAWARE GEOLOGICAL
SURVEY

✓ P. 32-11

AH 7'

1. Permit Number: 35121
Owner of Well: John R. Hitchcock

8. Well Head Completion:
Yes Pitless Adapter Baker Type
 inches above grade

2. Test Well
Observation Well
Production Well ✓
Well Abandoned? Yes No ✓

9. Static Water Level:
6 feet below grade
 feet above grade

3. Total Well Depth 86 feet
Date Completed 3-22-76

10. Pumping Water Level:
24 feet below grade after
2 hours at 171 GPM

4. Grout: Type Cement
from 0 feet to 64 feet
from feet to feet

11. Permanent Pump Installed?
Yes ✓ No
a. Shallow Well ✓
 Deep Well
b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
c. Capacity 100 GPM

5. Casing: Type 6" PVC
0 inches to 86 feet
 inches to feet
Drive Shoe? Yes No ✓

12. Well Number
(Leave Blank)

6. Screen Setting:
66 feet to 86 feet

7. Gravel Packed? Yes ✓ No
66 feet to 86 feet

no map in state file

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
medium yellow sand	5'	5'
" white "	5'	10'
fine "	5'	15'
" yellow "	10'	25'
" white "	10'	30'
coarse "	10'	40'
" " " + gravel	5'	45'
medium "	10'	55'
" fine "	10'	65'
coarse "	5'	70'
" " " + gravel	16'	86'

14. Signature of Water Well Contractor W. H. Burns

Date May 10, 1976