

WELL COMPLETION REPORT

1. Permit Number: 36733  
 Owner of Well: L. S. Fawcett

2. Test Well  
 Observation Well —  
 Production Well X  
 Well Abandoned? Yes — No X

3. Total Well Depth 37 feet  
 Date Completed 9-21-76

4. Grout: Type Cement  
 from 0 feet to 20 feet  
 from — feet to — feet

5. Casing: Type PVC  
4 inches to 37 feet  
— inches to — feet  
 Drive Shoe? Yes — No X

6. Screen Setting:  
27 feet to 37 feet

7. Gravel Packed? Yes X No —  
27 feet to 37 feet

13. Well Log

8. Well Head Completion:  
NO Pitless Adapter — Type  
— inches above grade

9. Static Water Level:  
6 feet below grade  
— feet above grade

10. Pumping Water Level:  
10 feet below grade after  
1 hours at 80 GPM

11. Permanent Pump Installed?  
 Yes — No X  
 a. Shallow Well —  
 Deep Well —  
 b. Reciprocating — Rotary —  
 Centrifugal — Jet —  
 Submersible —  
 c. Capacity — GPM

12. Well Number —  
 (Leave Blank)

SEE #37080  
 P. 34-08

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Fine brown sand	10	10
Coarse yellow sand w/gravel	5	15
med white sand	5	20
coarse brown sand w/gravel	5	25
coarse white sand	5	30
coarse white sand w/gravel	7	37

14. Signature of Water Well Contractor Date

W. H. Rimmer

10/26/76