

STATE OF DELAWARE  
 WATER AND AIR RESOURCES COMMISSION  
 Water Resources Division  
 Dover, Delaware 19901

WRD-2  
 7/69

P134-14

WELL COMPLETION REPORT

Test Well # 4-A

1. Permit Number: 35476  
 Owner of Well: Indian Landing M.H. Park

2. Test Well  
 Observation Well   
 Production Well   
 Well Abandoned? Yes  No

3. Total Well Depth 25 feet  
 Date Completed Jan. 13, 1976

4. Grout: Type Cement  
 from 15 feet to 2 feet  
 from          feet to          feet

5. Casing: Type Gal. Steel  
2 inches to 21 feet  
         inches to          feet  
 Drive Shoe? Yes  No

6. Screen Setting:  
21 feet to 25 feet

7. Gravel Packed? Yes  No   
20 feet to 25 feet

8. Well Head Completion:  
 Pitless Adapter          Type  
12 inches above grade

9. Static Water Level:  
4 feet below grade  
 feet above grade

10. Pumping Water Level:  
20 feet below grade after  
2 hours at 50 GPM

11. Permanent Pump Installed?  
 Yes  No   
 a. Shallow Well   
 Deep Well   
 b. Reciprocating  Rotary   
 Centrifugal  Jet   
 Submersible   
 c. Capacity          GPM

12. Well Number           
 (Leave Blank)

• 50 P.P.M. N.A.C.L.  
 after 2 hrs pumping

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
top soil	1	1
browned yellow fine & medium sand	3	4
light yellow dirty fine & medium sand	3	7
yellow & clayey sand	9	16
fine to coarse white fairly clean sand	11	27
slightly dirty fine to coarse white sand	4	31

14. Signature of Water Well Contractor Paul C. White & Sons Inc Date Jan 15, 1976