

Q634-02

BL-13

Sha

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

WD-2
1/69

WELL COMPLETION REPORT

1. Permit Number: WR-6-1039/1972
 Owner of Well: Herman DICKERSON

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 60 feet
 Date Completed 12/10/72

4. Grout: Type bedonite
 from 3 feet to 20 feet
 from feet to feet

5. Casing: Type PVC
2" inches to 55 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
55 feet to 60 feet

7. Gravel Packer? Yes No
50 feet to 60 feet

8. Well Head Completion:
 Pileup inches above grade Type
 inches above grade NONE

9. Static Water Level:
4 feet below grade
 feet above grade

10. Pumping Water Level:
21 feet below grade after
1 1/2 hours at 30 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity 25 GPM

12. Well Number
 (Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top Soil	0	1
Tan sand	1	10
White sand	10	35
White sand w/ clay	35	40
Fine tan sand	40	50
red tan sand	50	60

14. Signature of Water Well Contractor Delmarva Drilling Co Date 12/29/72

(over)