

MAIL TO:

WATER SUPPLY SECTION
DIVISION OF WATER RESOURCES
89 KINGS HIGHWAY
DOVER, DELAWARE 19901
PHONE: 302-739-3665
FAX: 302-739-2296

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED WITHIN 30 DAYS OF
CONSTRUCTION DATE

FORMATION LOG

Qc13-14

PAGE 2 OF 2 PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT# 178782	LOCAL ID# IW1	
PROPERTY OWNER Glen Eskridge		
WELL CONTRACTOR ACS D	LIC# 14	
DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
top soil	0	1
Med Tan Sand	1	18
Med-Coarse White Sand	18	53
Hard layer	53	54
Med Orange Sand	54	64
Med Tan Sand	64	71
Fine Gray Sand w/Gray Clay	71	75
Test well is Qc13-20		

OTHER COMMENTS:

RECEIVED
JUL 11 2001
WATER SUPPLY

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Signature of Well Driller in Charge Kenneth Steyer License# 4153 Date 06-25-01