

*HW*

WELL COMPLETION REPORT

1. Permit Number: 36598  
 Owner of Well: Derby Walker

2. Test Well  
 Observation Well   
 Production Well   
 Well Abandoned? Yes  No

3. Total Well Depth 76 feet  
 Date Completed July 19, 1976

4. Grout: Type none  
 from      feet to      feet  
 from      feet to      feet

5. Casing: Type Galv. Steel  
2 inches to 72 feet  
     inches to      feet  
 Drive Shoe? Yes  No

6. Screen Setting:  
72 feet to 76 feet

7. Gravel Packed? Yes  No   
70 feet to 76 feet

8. Well Head Completion:  
Pitless Adapter Type  
12 inches above grade

9. Static Water Level:  
15 1/2 feet below grade  
     feet above grade

10. Pumping Water Level:  
24 feet below grade after  
2 hours at 60 GPM

11. Permanent Pump Installed?  
 Yes  No   
 a. Shallow Well   
    Deep Well   
 b. Reciprocating  Rotary   
    Centrifugal  Jet   
    Submersible   
 c. Capacity      GPM

12. Well Number       
 (Leave Blank)

*QC33-09*

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
top soil		
clayey tan sand	1	1
gray clay	5	6
clayey light gray sand	2	8
gray & yellow clay	3	11
fine to coarse white sand + gravel	8	19
same but yellow	23	42
very fine to coarse yellow sand	4	46
fine to coarse orange sand + gravel	6	52
same yellow	7	59
fine to coarse orange sand + gravel	10	69
same yellow	10	69
very fine to some very coarse yellow sand	2	71
fine to coarse yellow + white sand	5	76

14. Signature of Water Well Contractor Date  
P.E. White + Sons inc. July 24, 1976