

SH # EI-401 Qc 52-7

MAIL TO:
WATER SUPPLY DIVISION
DIVISION OF ENVIRONMENTAL CONTROL
P.O. BOX 1301
DOVER, DELAWARE 19901

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL RECORDS MONTHLY MUST
BE RETURNED 21 DAYS AFTER
CONSTRUCTION DATE

WELL COMPLETION REPORT

PLEASE PRINT

FEDERAL NO. 60031 (LOCAL ID 101)

WELL # Seaside Farms

CONSTRUCTION DATE 4-10-85

PURPOSE TEST PERMANENT

USE DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify)

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL _____

ABANDONMENT METHOD _____

TYPE OF PERMANENT PUMP INSTALLED

PUMP MANUFACTURE _____

RATED CAPACITY (GPM) 7

PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

A AT LEAST 5' FROM ANY OVERHANG YES NO

B AT LEAST 50' FROM ANY SEPTIC TANK

C AT LEAST 10' FROM TOWN SEWER LINE

D AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS _____ FROM COMPLETED WELL

IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS _____

DRILLING METHOD

AUGERED BORED CABLE TOOL

DRIVEN JETTED AIR ROTARY

MUD ROTARY REVERSE WASHED

OTHER (Specify)

TOTAL DEPTH DRILLED 89

CASING SEQUENCE

	1st	2nd	3rd	4th
CASING TOP	1			
CASING BOTTOM	29			
CASING DIAMETER	12			
CASING MATERIAL	pc			

SCREEN SEQUENCE

	1st	2nd	3rd	4th
SCREEN TOP	28			
SCREEN BOTTOM	89			
SCREEN DIAMETER	12			
SCREEN MATERIAL	pc			

GROUT TYPE CEMENT BENTONITE CLAY

OTHER _____

FROM 3 TO 20 FEET

NON-GROUT BACKFILL OF WELL ANNULUS TYPE SAND FROM _____ TO _____ FEET

GRAVEL BACK TYPE grit

FROM 20 TO 89 FEET

STATIC WATER LEVEL DATE 4-10-85

0 FT. (below/above) GROUND SURFACE

PUMPING WATER LEVEL 13 FT. BELOW GRADE

AFTER 5 HOURS AT 90 GPM

WELL HEAD COMPLETION:

TYPE LESS ADAPTOR

CHEEK

12 INCHES ABOVE GRADE

Qc 52-07

RECEIVED

MAY 28 1985

WATER SUPPLY

1200' 1900'

24

DRILLER'S LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0	1
White Sand & clay	1	18
White Sand & gravel	18	55
Thin Sand & gravel	55	89

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE AQUIFER MUST BE OBTAINED FROM DNREC

SUPPLEMENTAL DRILLER'S LOG ATTACHED YES NO

PAGE 1 OF _____ PAGES

COMPANY NAME Safety Well Drilling

SIGNATURE OF DRILLER IN CHARGE [Signature] DATE _____

Document 20-06/78/05/10



HALL OF RECORDS - 2

DOCUMENT NO. 10 28-78-01-03

WHITE - DNREC CANARY - CONTRACTOR PINK - OWNER