



STATE OF DELAWARE  
WATER AND AIR RESOURCES COMMISSION  
Water Resources Division  
Dover, Delaware 19901



NOV 19 1975



STATE OF DELAWARE  
WATER RESOURCES SECTION

WELL COMPLETION REPORT

DELAWARE GEOLOGICAL  
SURVEY

1. Permit Number: 31830  
Owner of Well: Broad Creek Druggists

8. Well Head Completion:  
Yes Pitless Adapter Baker Type  
\_\_\_\_\_ inches above grade

2. Test Well  
Observation Well \_\_\_\_\_  
Production Well   
Well Abandoned? Yes \_\_\_\_\_ No

9. Static Water Level:  
8 feet below grade  
\_\_\_\_\_ feet above grade

3. Total Well Depth 52 feet  
Date Completed 11-4-75

10. Pumping Water Level:  
15 feet below grade after  
2 hours at 50 GPM

4. Grout: Type Asbestom  
from 0 feet to 45 feet  
from \_\_\_\_\_ feet to \_\_\_\_\_ feet

11. Permanent Pump Installed?  
Yes  No \_\_\_\_\_  
a. Shallow Well   
Deep Well \_\_\_\_\_  
b. Reciprocating \_\_\_\_\_ Rotary \_\_\_\_\_  
Centrifugal \_\_\_\_\_ Jet   
Submersible \_\_\_\_\_  
c. Capacity 10 GPM

5. Casing: Type 2" PVC  
0 inches to 52 feet  
\_\_\_\_\_ inches to \_\_\_\_\_ feet  
Drive Shoe? Yes \_\_\_\_\_ No

12. Well Number \_\_\_\_\_  
(Leave Blank)

6. Screen Setting:  
47 feet to 52 feet

location map on back

7. Gravel Packed? Yes  No \_\_\_\_\_  
47 feet to 52 feet

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
fine brown sand w/ clay	5'	5'
coarse yellow "	5'	10'
medium brown "	10'	20'
fine white "	10'	30'
medium brown "	10'	40'
coarse " "	12'	52'

14. Signature of Water Well Contractor H. Burns Date 11-10-75