

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

Qd 21-18
 LRD-7
 716

WELL COMPLETION REPORT

1. Permit Number: 35248
 Owner of Well: Jessie H. Hill

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 37 feet
 Date Completed 11-23-75

4. Grout: Type Concrete
 from 9 feet to 18 feet
 from feet to feet

5. Casing: Type PVC
0 inches to 32 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
34 feet to 37 feet

7. Gravel Packed? Yes No
30 feet to 37 feet

8. Well Head Completion:
No Pitless Adapter Type
 inches above grade

9. Static Water Level:
18 feet below grade
 feet above grade

10. Pumping Water Level:
25 feet below grade after
1 hours at 10 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

Qd 21-18

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top soil	0	1
black dirt	1	2
gray clay	2	8
gray sand-red	8	15
1/2 tan sand with clay	15	20
gray sand-red	20	30
gray sand-chalk	30	37

14. Signature of Water Well Contractor Jessie Hill Date 11-30-75

(over)

ON MUST BE
 AND PERMIT
 BEFORE DRILLING

Day 25 Year

No. 22
 No.

607A.C
 24 RIGHT

Permit No. 35248

available)

to a well as des-
 red. The following

35248
11/23/75