

OR
TTH
RTY
ELL
RNE

STATE OF DELAWARE
DIVISION OF ENVIRONMENTAL CONTROL
DOVER, DELAWARE 19903

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED 30 DAYS AFTER
CONSTRUCTION DATE

WELL COMPLETION REPORT

Qd 44-04

PLEASE PRINT

PERMIT NO. 74473 ✓ LOCAL ID _____

OWNER LAWRENCE DOWNES

CONSTRUCTION DATE 6/17/88

PURPOSE TEST PERMANENT

USE DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO
ABANDONMENT DATE FOR OLD WELL _____
ABANDONMENT METHOD _____

DRILLING METHOD
 AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____
TOTAL DEPTH DRILLED 58

CASING SEQUENCE

DEPTH	SIZES
0	
48	
20	
	PVC

SCREEN SEQUENCE

DEPTH	SIZES
48	
58	
	PVC

GROUT TYPE: CEMENT BENTONITE CLAY
OTHER: _____
FROM 0 TO 20 FEET
NON-GROUT BACKFILL OF WELL ANNULUS
TYPE SAND FROM 20 TO 48 FEET
GRAVEL PACK TYPE MURPHY NO. 2
FROM 48 TO 58 FEET

STATIC WATER LEVEL: DATE 6/17/88
1 FT (Below, above) GROUND SURFACE
PUMPING WATER LEVEL: 1 FT BELOW GRADE
AFTER 2 HOURS AT 20 GPM.

WELL HEAD COMPLETION:
TYPE: PITLESS ADAPTOR
OTHER _____
8 INCHES ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE DONT KNOW

RATED CAPACITY (GPM) _____
PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?
A. AT LEAST 15' FROM ANY FOUNDATION YES NO
B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
D. AT LEAST 100' FROM THE NEAREST EDGE YES NO
OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)
 SEPTIC TILE FIELD CESSPOOL OR PRIVY
IS 150 FEET FROM COMPLETED WELL.
IS COMPLETED WELL LOCATED AS SHOWN
ON APPLICATION FORM? YES NO
IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

RECEIVED
JUN 23 1988
W
WATER SUPPLY

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
SAND CLAY	0	15
WHITESAND	15	45
TENSAND	45	58

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF _____ PAGES
COMPANY NAME _____
SIGNATURE OF DRILLER IN CHARGE: Robert English DATE 6/17/88

DOCUMENT NO. 44-88-78-41-43

WHITE - DNRSC

CANARY - CONTRACTOR

PINK - OWNER

Document 20-06/78/05/10

24774

247