

Qd45-03

1. Permit Number: 37354  
 Owner of Well: Robert Whaley

2. Test Well \_\_\_\_\_  
 Observation Well \_\_\_\_\_  
 Production Well   
 Well Abandoned? Yes \_\_\_ No \_\_\_

3. Total Well Depth 124 feet  
 Date Completed 4/23/77

4. Grout: Type Cement  
 from 5 feet to 16 feet  
 from \_\_\_\_\_ feet to \_\_\_\_\_ feet

5. Casing: Type PVC  
0 inches to 24 feet  
 \_\_\_\_\_ inches to \_\_\_\_\_ feet  
 Drive Shoe? Yes \_\_\_ No

6. Screen Setting:  
24 feet to 124 feet

7. Gravel Packed? Yes  No \_\_\_  
25 feet to 124 feet

10. Pumping Water \_\_\_\_\_  
80 feet \_\_\_\_\_  
 hours \_\_\_\_\_

11. Permanent Pump Installed?  
 Yes \_\_\_ No   
 a. Shallow Well \_\_\_\_\_  
 Deep Well \_\_\_\_\_  
 b. Reciprocating \_\_\_\_\_ Rotary \_\_\_\_\_  
 Centrifugal \_\_\_\_\_ Jet \_\_\_\_\_  
 Submersible \_\_\_\_\_  
 c. Capacity \_\_\_\_\_ GPM

12. Well Number \_\_\_\_\_  
 (Leave Blank)

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top Soil	0	1
Red sand - fine	1	5
tan clay	5	12
Red sand - Med.	13	18
tan sand - Med coarse	17	25
15 tan clay	55	60
red sand - Med coarse	60	80
15 tan sand - Med coarse	55	90
Red sand - Red	90	124

Signature of Water Well Contractor

Date

Robert Whaley

4/23/77