

MAIL TO:
 WATER SUPPLY BRANCH
 DIVISION OF ENVIRONMENTAL CONTROL
 P O BOX 1401
 DOVER, DELAWARE 19901

STATE OF DELAWARE
 DEPARTMENT OF NATURAL RESOURCES
 AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
 BE RETURNED 21 DAYS AFTER
 CONSTRUCTION DATE

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO 54461 LOCAL ID _____

OWNER Del. Solid Waste

CONSTRUCTION DATE September 6, 1983
 PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO
 ABANDONMENT DATE FOR OLD WELL _____
 ABANDONMENT METHOD _____

DRILLING METHOD
 AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____
 TOTAL DEPTH DRILLED 26'

CASING SEQUENCE

	1st	2nd	3rd	4th
CASING TOP	0			
CASING BOTTOM	15'			
CASING DIAMETER	2"			
CASING MATERIAL	PVC			

SCREEN SEQUENCE

	1st	2nd	3rd	4th
SCREEN TOP	15'			
SCREEN BOTTOM	25'			
SCREEN DIAMETER	2"			
SCREEN MATERIAL	PVC			

GROUT TYPE: CEMENT BENTONITE CLAY
 OTHER: _____
 FROM 0 TO 5 FEET
 NON-GROUT BACKFILL OF WELL ANNULUS
 TYPE _____ FROM _____ TO _____ FEET
 GRAVEL PACK: TYPE #2
 FROM 5 TO 25 FEET

STATIC WATER LEVEL: DATE September 6, 1983
5 FT. (Below, above) GROUND SURFACE
 PUMPING WATER LEVEL: 20 FT. BELOW GRADE
 AFTER 2 HOURS AT 40 GPM.

WELL HEAD COMPLETION:
 TYPE: P.T.L.E.S. ADAPTOR
 OTHER _____
 _____ INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE NA
 RATED CAPACITY (GPM) _____
 PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?
 YES NO
 A. AT LEAST 5' FROM ANY OVERHANG
 B. AT LEAST 50' FROM ANY SEPTIC TANK
 C. AT LEAST 10' FROM TOWN SEWER LINE
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)
 SEPTIC TILT FIELD CESSPOOL OR PRIVY
 IS _____ FROM COMPLETED WELL
 IS COMPLETED WELL LOCATED AS SHOWN
 ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS

De 14-09
 RECEIVED
 OCT 6 1983
 WATER SUPPLY

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0	1
Gray loam sand	1	2
Fine med brown sand	2	21
Fine coarse basalt	21	26

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF 1 PAGES
 COMPANY NAME Delmarva Drilling Company
 SIGNATURE OF DRILLER IN CHARGE Ed Kelley DATE 10/1/83