

MAIL TO:

WATER SUPPLY BRANCH
DIVISION OF ENVIRONMENTAL CONTROL
P.O. BOX 1401
DOVER, DELAWARE 19903

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED 30 DAYS AFTER
CONSTRUCTION DATE

PLEASE PRINT

WELL COMPLETION REPORT

0914-12

PERMIT NO. 87634 LOCAL ID R4-1

OWNER ULASIS Foods Inc.

CONSTRUCTION DATE 7-16-91

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 OBSERVATION DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) Recovery well

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL N/A

ABANDONMENT METHOD N/A

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 45'

CASING SEQUENCE

INNER	OUTER
+2	
-20	
6"	
PVC	

SCREEN SEQUENCE

INNER	OUTER
-20	
-40	
6"	
Steel	

WRITTEN APPROVAL FOR SCREENING/
GRAVEL PACKING MORE THAN ONE ADU-
PHER MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT BENTONITE CLAY

OTHER: _____

FROM 0 TO 18 FEET

NON-GROUT BACKFILL OF WELL ANNULUS

TYPE _____ FROM _____ TO _____ FEET

GRAVEL PACK: TYPE Ricci #2

FROM 18 TO 45 FEET

STATIC WATER LEVEL: DATE 7/17/91

-20 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 29 FT. BELOW GRADE

AFTER 24 HOURS AT 125 GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR

OTHER Well be Above Ground Well Seal

24 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE Nat Installed yet

RATED CAPACITY (GPM) _____

PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

- YES NO
- A. AT LEAST 15' FROM ANY FOUNDATION
- B. AT LEAST 50' FROM ANY SEPTIC TANK
- C. AT LEAST 10' FROM TOWN SEWER LINE
- D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD


THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS _____ FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top Soil	0	1
Li. Yellow fine/med sand	1	3
Li. Brown fine/med sand	3	7
Thin Fine sand	7	15
Thin Fine/med. Sand	15	24
White Fine Sand	24	29
Gray Fine Sand	29	34
Yellow Fine Sand	34	45

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF _____ PAGES

COMPANY NAME Fitch Data Inc

SIGNATURE OF DRILLER IN CHARGE: Norman F Sullivan DATE 8.7.91