

STATE OF CALIFORNIA
 DEPARTMENT OF NATURAL RESOURCES
 AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
 BE RETURNED 31 DAYS AFTER
 CONSTRUCTION DATE

BRANCH
 TER RESOURCES
 ARE 1988

WELL COMPLETION REPORT

PLANT NO. 71935 LOCAL ID. V-4

OWNER Orangevale Road's

CONSTRUCTION DATE 11-19-87

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 RECREATION PUBLIC
 IRRIGATION OTHER (Specify) _____
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL _____

ABANDONMENT METHOD Replaced & Grouted

DRILLING METHOD: AUGURED BORED CABLE TOOL
 DRIPPIN JETTED AIR ROTARY
 MAJ. ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 44

CASING GEOSOURCE

CASING TOP	2.0	FEET
CASING BOTTOM	20.0	FEET
CASING DIAMETER	4"	
CASING MATERIAL	PVC	

SCREEN GEOSOURCE

SCREEN TOP	25.0	FEET
SCREEN BOTTOM	40.0	FEET
SCREEN DIAMETER	4"	
SCREEN MATERIAL	PVC	

OTHER: BENTONITE CLAY

FROM 11 TO 2 FEET

NON-CROUT PACKFILL OF WELL ANNULUS

TYPE _____ FROM _____ FEET

GRAVEL PACK TYPE Gravel

FROM _____ TO _____ FEET

STATIC WATER LEVEL DATE 11.23.87

42.2 FT. BELOW GROUND SURFACE

PUMPING WATER LEVEL 1.0 FT. BELOW GRADE

AFTER 1/2 HOURS AT 2.0 GPM

WELL HEAD COMPLETION

TYPE: FITLESS ADAPTOR

OTHER:

_____ INCHES ABOVE GRADE

PUMP MANUFACTURE _____

RATED CAPACITY (GPM) _____

PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS:

A. AT LEAST 8' FROM ANY OVERHANG YES NO

B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO

C. AT LEAST 10' FROM TOWN SEWER LINE YES NO

D. AT LEAST 100' FROM THE NEAREST EDGE YES NO

OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE):

SEPTIC TANK FIELD CESSPOOL OR PRIVY

IS _____ FROM COMPLETED WELL

IS COMPLETED WELL LOCATED AS SHOWN

ON APPLICATION POINT

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS

Original well

BEERIVE

FEB 17 1988

WATER SUPPLY

091120

DRILLER LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Brown sand	0	4.5
heavy clay	4.5	8.0
wh. to Sandy Clay	8.0	10.0
Tan Sand	10.0	13.0
white fine sand	13.0	29.0
white fine sand	29.0	39.0
Tan m. to fine sand	39.0	44.0

TYPE OF WELL: VES NO

CLASSIFY - COMPLETION: Car-M Data, Inc

DATE: 11-7-87

Signature of Well Owner: Tracie Marshall