

Area Hard - Varies Country - Use Test-Point Plan or Typewriter - Print Name **38930**

Mail To:	Water Supply Section Division of Environmental Control Vehicle Building Dover, Delaware 19901	STATE OF DELAWARE DEPARTMENT OF NATURAL RESOURCES AND ENVIRONMENTAL CONTROL	APPLICATION MUST BE SUBMITTED AND PERMIT RECEIVED BEFORE DRILLING IS STARTED.
To be completed by a licensed water well driller			
Charles Shultz Telephone Number (302) 463-2129		Date of Application 8 May 77	APPLICATION NUMBER 38930
Address 11113 Bay Rd., Suite 700 Mt. Pleasant, DE 19966		Estimated Date of Construction 8-15-77	
Driller Burnell License No. 7		Pump Supplier None	
WELL INFORMATION (Provide one)			
Purpose Test Well - Commercial - Option to convert Use <input checked="" type="checkbox"/> Public - Commercial Industrial - Agriculture - Other			
Desired volume? _____			
Is this a replacement well? <input checked="" type="checkbox"/> Yes Reason for replacement? diminished flow			
Date abandoned well is to be tested _____			
Holes _____			
Has an application been made for an approved sewage disposal system? <input checked="" type="checkbox"/> Yes			
Permit Number: _____			
PROPOSED WELL CONSTRUCTION			
Method of drilling drill rig			
Approximate final depth of well 55 ft			
Name of driller _____			
Casing diameter 4"			
Inner or outer 5"			
Casing Material: PVC			
Screen Material: PVC			
Tentative Screen Setting between 5 and 55 ft			
Estimated length of screen 5 ft			
Will the well be gravel packed? <input checked="" type="checkbox"/>			
Type of grout none			
Desired capacity of the well 150 gpm			
Maximum static level 50 ft			
I hereby affirm the information I have furnished is correct and complete.			
Charles Shultz Applicant (Print) Residential			
For official use Only - Do Not Write Below This Line			
Permitted by provisions of 7 Delaware Code, Chapter 6A, permission to bury ground or well is given and no a well or other artifical drain. All current regulations governing well construction and water resources use must be followed. The following conditions must be observed. 9/19/73 Rud J. Bryan			
This permit number: 38930			
An application report must be filed with the Division of Environmental Control within twenty-one (21) days after completion of this well. Failure to do so may result in license revocation.			

Site Plan (Include suitable plot plan if available)

STATE OF DELAWARE
Division of Water Resources
Dover, Delaware 19901
WELL COMPLETION REPORT
Q91512

1. Permit Number: **38930**
Charles Shultz

2. Test Well
Observation Well _____
Production Well _____
Well Abandonment _____

3. Static Water Level:
18 feet below grade
feet above grade

4. Total Well Depth: **57** feet
Date Completed: **7-14-77**

5. Gravel: Type **Native**
from **52** feet to **57** feet
from **52** feet to **57** feet

6. Casing: Type **2" PVC**
0 inches to **57** feet
inches to **57** feet
Drive Sheet Yes **No**

7. Screen Setting: **52** feet to **57** feet

8. Gravel Packed? Yes **No**
52 feet to **57** feet

12. Well Number _____
(Leave Blank)

Formation	Thickness of Gravel	Depth to Bottom of Gravel
fine white sand	10'	10'
medium brown	10'	20'
medium brown	20'	40'
orange	17'	57'

Signature of Water Well Contractor: **Burnell** Date: **7-14-77**

Document 10-06778/07/10

FILE S

STATE OF DELAWARE