

MAIL TO:  
 WATER SUPPLY SECTION  
 DIVISION OF WATER RESOURCES  
 89 KINGS HIGHWAY  
 DOVER, DELAWARE 19901  
 PHONE: 302-739-9944  
 FAX:302-739-7764

STATE OF DELAWARE  
 DEPARTMENT OF NATURAL RESOURCES  
 AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST  
 BE RETURNED WITHIN 30 DAYS OF  
 CONSTRUCTION DATE

FORMATION LOG

PAGE        OF        PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT #: 231188 LOCAL ID#: ~~231188~~ Qg24-11 MSB-16

PROPERTY OWNER: DOT Sussex

WELL CONTRACTOR: DGS WC LIC #: 999

DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
From core		
SAND, very fine-fine; yellow-1ft gray, clean	0	8
SAND, fine-very fine; 1ft olive gray; mod silty w/ silt laminae	8	11
SILT, moderately clayey; olive gray; bioturb. with lenses silt	11	14
SAND, very fine-fine-grading down to fine-coarse; few plaque heavy mineral (shw) lam.	14	21
SAND, very fine-fine into bedded with coarse-very coarse; slightly-moderately silty	21	28
1ft gray from auger returns + gamma log interpretation		
Sand; very fine-fine interbedded with coarse-very coarse; slightly to moderately silty	28	65

COMMENTS:

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Signature of Well Driller in Charge of Construction [Signature] WD License # 586 Date 5/13/10