

11-20-84

11-20-84

PERMANENT

AGRICULTURAL

INDUSTRIAL

PUBLIC

DEWATERING

HEAT PUMP SUPPLY

PLACEMENT WELL? YES NO

DATE FOR OLD WELL NA

INSTALLATION METHOD NA

DRILLING METHOD

BORED CABLE TOOL

JETTED AIR ROTARY

REVERSE WASHED

DEPTH DRILLED 71'

CASING SEQUENCE

1st	2nd	3rd	4th
18"			
65'			
2"			
PVC			

SCREEN SEQUENCE

1st	2nd	3rd	4th
65'			
78'			
2"			
PVC			

CEMENT BENTONITE CLAY

TO 30 FEET

BACKFILL OF WELL ANNULUS

no FROM 30 TO 60 FEET

PIPE TYPE Riser

TO 70 FEET

PERMIT DATE 11-20-84

(flow, above) GROUND SURFACE

WATER LEVEL 20 FT BELOW GRADE

OPERATING HOURS AT 20 GPM

COMPLETION:

IS ADAPTOR

PVC pipe

FEET ABOVE GRADE

PUMP MANUFACTURE NA

RATED CAPACITY (GPM) NA

PUMP INTAKE SETTING NA FT BELOW GRADE

59270 THE COMPLETED WELL IS?

YES NO

A. AT LEAST 5' FROM ANY OVERHANG

B. AT LEAST 50' FROM ANY SEPTIC TANK

C. AT LEAST 10' FROM TOWN SEWER LINE

D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS 100 FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS

Q: 2⁴ - 17

DRILLERS LOG DESCRIPTION | TOP OF STRATA | BOTTOM OF STRATA

Top Soil	0	1
Thin red sand	1	5
Thin red sandy clay	5	30
" " " " sand	30	60
Thin coarse red sand	60	70

SUPPLEMENTAL DRILLERS LOGS ATTACHED YES NO

PAGE 1 OF 1 PAGES

COMPANY NAME Tri-Stat

SIGNATURE OF DRILLER Joe Piner DATE 11-20-84