

9-185  
(October 1950)

UNITED STATES  
DEPARTMENT OF THE INTERIOR  
GEOLOGICAL SURVEY  
WATER RESOURCES DIVISION

WELL SCHEDULE

Date Aug. 4, 1955 Field No. Qi 34-1  
Record by R. A. Wilkens Office No. Q-3  
Source of data Mr. Charles Aydelotte (Millville 273)

1. Location: State Delaware County Sussex

Map \_\_\_\_\_

2. Owner: Millville Fire Co Address Millville  
Tenant \_\_\_\_\_ Address \_\_\_\_\_  
Driller Ennis Bros. Address Odessa

3. Topography Coastal Plain


4. Elevation 12 ft. above msl  
85 ft. below \_\_\_\_\_

5. Type: Dug,  drilled,  driven, bored, jetted 8/18 19 43

6. Depth: Rept. 85 ft. Meas. \_\_\_\_\_ ft.

7. Casing: Diam. 6 in., to \_\_\_\_\_ in., Type \_\_\_\_\_

Depth \_\_\_\_\_ ft., Finish 20' screen



8. Chief Aquifer \_\_\_\_\_ From \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Others \_\_\_\_\_

9. Water level 8' ft.  repl. 19.53 above meas. below \_\_\_\_\_

\_\_\_\_\_ which is \_\_\_\_\_ ft. above below surface

10. Pump: Type Turbine Capacity \_\_\_\_\_ G. M.

Power: Kind Electric Horsepower 5

11. Yield: Flow \_\_\_\_\_ G. M., Pump \_\_\_\_\_ G. M., Meas., Rept. Est. \_\_\_\_\_

Drawdown \_\_\_\_\_ ft. after \_\_\_\_\_ hours pumping \_\_\_\_\_ G. M.

12. Use: Dom., Stock, PS., RR., Ind., Irr., Obs. Fire Use

Adequacy, permanence \_\_\_\_\_

13. Quality see driller Temp \_\_\_\_\_ °F.

Taste, odor, color good drinking water Sample  Yes  No

Unfit for \_\_\_\_\_

14. Remarks: (Log, Analyses, etc.) water about 50'

20' well tested

Qi 34-1

0-20 Clay and sand

20-63 Sand and clay white and red

63-84 Sand

60' pipe 120 gpm

30' pipe 85 gpm

85' deep

65' from top of casing to top of packer

69' -1"6" casing

3 30 gauge well screen

3 4" couplings

1 4 1/2" lead packer

1 4" plug

Qi 34-1