

WELL COMPLETION REPORT

64949 LOCAL ID _____
William, Elizabeth
 DATE 5-12-86
 TEST PERMANENT
 DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____
 REPLACEMENT WELL? YES NO
 REMOVAL DATE FOR OLD WELL _____
 REMOVAL METHOD _____

DRILLING METHOD
 BORED CABLE TOOL
 JETTED AIR ROTARY
 REVERSE WASHED
 (Specify) _____
 DEPTH DRILLED 57

CASING SEQUENCE

INNER	OUTER
14	
51	
2	
PVC	

SCREEN SEQUENCE

INNER	OUTER
51	
57	
2	
PVC	

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE FOOTER MUST BE OBTAINED FROM OMBEC

TYPE: CEMENT BENTONITE CLAY
 FEET TO FEET
 BACKFILL OF WELL ANNULUS 42'
 PACK TYPE 3/32
 FEET TO FEET
 WATER LEVEL DATE 5-12-86
 (Below, above) GROUND SURFACE
 WATER LEVEL: 27 FT. BELOW GRADE
2 HOURS AT 50 GPM.

COMPLETION:
 FLESS ADAPTOR

 CHECKS ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:
 PUMP MANUFACTURE _____
 RATED CAPACITY (GPM) _____
 PUMP INTAKE SETTING _____ FT. BELOW GRADE
THE COMPLETED WELL IS?
 YES NO
 A. AT LEAST 5' FROM ANY OVERHANG
 B. AT LEAST 50' FROM ANY SEPTIC TANK
 C. AT LEAST 10' FROM TOWN SEWER LINE
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD
THE NEAREST NEIGHBORS (CIRCLE ONE)
 SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS 100 FROM COMPLETED WELL.
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

RECEIVED

FEB 17 1987

WATER SUPPLY

Q: 44-03

54
20
74

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Reddish clay shale	0	6"
white clay sand	6"	1'
white wet fine sand	1'	4'
gray wet	4'	17'
gray clay shale	17'	49'
broken wood	49'	54'
fine sand		
coarse fairly clean sand	54'	57'
broken wood	57'	70'

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF 1 PAGES
 COMPANY NAME White Drilling Corp
 SIGNATURE OF DRILLER IN CHARGE R. Allen White Sr. DATE 5/12/86