

1. Permit Number: 37077
 Owner of Well: Schmidt Const. Co.

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 66 feet
 Date Completed 9/12/76

4. Grout: Type None
 from feet to feet
 from feet to feet

5. Casing: Type Galv.
2 inches to 66 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
6.1 feet to 66 feet

7. Gravel Packed? Yes No
6.1 feet to 66 feet

13. Well Log

8. Well Head Completion:
 Pitless Adapter Type
 inches above grade

9. Static Water Level:
7 feet below grade
 feet above grade

10. Pumping Water Level:
10 feet below grade after
1 hours at 50 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

| Formation | Thickness of Stratum | Depth to Bottom of Stratum |
|-------------------|----------------------|----------------------------|
| coarse white sand | 10 | 10 |
| fine grey sand | 10 | 20 |
| blue clay | 10 | 30 |
| med grey sand | 10 | 40 |
| med white sand | 15 | 55 |
| coarse white sand | 11 | 66 |
| | | |
| | | |

14. Signature of Water Well Contractor Will H. Burns Date 10/26/76