

MAIL TO:

WATER SUPPLY SECTION
 DIVISION OF WATER RESOURCES
 89 KINGS HIGHWAY
 DOVER, DELAWARE 19901
 PHONE: 302-739-3665
 FAX: 302-739-2296

STATE OF DELAWARE
 DEPARTMENT OF NATURAL RESOURCES
 AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
 BE RETURNED WITHIN 30 DAYS OF
 CONSTRUCTION DATE

FORMATION LOG

Q:44-08

PAGE _____ OF _____ PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT#	LOCAL ID#	PROPERTY OWNER	WELL CONTRACTOR	DESCRIPTION	TOP OF STRATA	LIC#	BOTTOM OF STRATA
164676		CMF Bayside L.L.C.	White			/	
				top soil	0		1
				silty tan sand Q _{sc} ? or Q _{cs}	1		6
				med yellow sand	6		28
				med gray sand	28		36
				gray clay & silt	36		78
				med gray sand T _{bd}	78		112
				med gray sand & wood T _{bt}	112		148
				gray clay	148		198
				med gray sand	198		240
				Alt: 17			
				6			

OTHER COMMENTS: _____

RECEIVED
 JUN 04 1999
 WATER SUPPLY

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Signature of Well Driller In Charge
 Roy E White

License# _____ Date 5/28/99

White - DNREC • Canary - Contractor • Pink - Owner