

PLANT NO. 1745 LOCAL ID _____

TYPE OF PERMANENT PUMP INSTALLED:

OWNER Harry K. Mearns

PUMP MANUFACTURE Grundfos

CONSTRUCTION DATE 11-25-86

RATED CAPACITY (GPM) _____
PUMP INTAKE SETTING _____ FT. BELOW GRADE

TEST PERMANENT
 DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

67463
THE COMPLETED WELL IS?
YES NO
A. AT LEAST 5' FROM ANY OVERHANG
B. AT LEAST 50' FROM ANY SEPTIC TANK
C. AT LEAST 10' FROM TOWN SEWER LINE
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

IS A REPLACEMENT WELL? YES NO
INSTALLMENT DATE FOR OLD WELL N/A
INSTALLMENT METHOD N/A

THE NEAREST NEIGHBORS (CIRCLE ONE)
SEPTIC TILE FIELD CESSPOOL OR PRIVY
IS _____ FROM COMPLETED WELL. Central Sewage
IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

DRILLING METHOD
 AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 AIR ROTARY REVERSE WASHED
OTHER (Specify) _____
TOTAL DEPTH DRILLED 90'

CASING SEQUENCE

DEPTH	DIAMETER
+2'	
40'	
4"	
PVC	

SCREEN SEQUENCE

DEPTH	DIAMETER
40'	
90'	
4"	
PVC	

WRITTEN APPROVAL FOR SCREENING: GRAVEL PACKING MORE THAN ONE ANCHOR MUST BE OBTAINED FROM STATE.

OUT TYPE: CEMENT BENTONITE CLAY
DEPTH: _____
DRAINAGE: _____ TO _____ FEET
GROUT BACKFILL OF WELL ANNULUS
EFFECTIVE FROM _____ TO _____ FEET
LEVEL PACK: TYPE #2
DEPTH: _____ TO _____ FEET
POTABLE WATER LEVEL: DATE 11-25-86
_____ FT. (Below, above) GROUND SURFACE
PUMPING WATER LEVEL: 17 FT. BELOW GRADE
RUN _____ HOURS AT 60 GPM.

RECEIVED
QJ31-03
DEC 31 1986
WATER SUPPLY
205 10L
TAK
4/11/00

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top Soil	0	1
Sub Fine Sand w/Clay	1	16
Very Fine Sand w/Gray Clay	16	41
White Sand & Coarse Sand	41	50
Gray Clay	50	52
Heavy Fines Coarse	52	88
Heavy Clay	88	100

WELL HEAD COMPLETION:
TYPE: PITLESS ADAPTOR
_____ INCHES ABOVE GRADE.

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF _____ PAGES
COMPANY NAME AWIS
SIGNATURE OF DRILLER IN CHARGE: Paul McCree/jc DATE 12/28/86