

MAIL TO:

WATER SUPPLY SECTION
DIVISION OF WATER RESOURCES
89 KINGS HIGHWAY
DOVER, DELAWARE 19901
PHONE: 302-739-3665
FAX: 302-739-2296

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED WITHIN 30 DAYS OF
CONSTRUCTION DATE

FORMATION LOG

Qj32-31

PAGE 1 OF 1 PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT# 168512-W		LOCAL ID#	
PROPERTY OWNER CAROL MCCORMICK			
WELL CONTRACTOR SOMERSET WELL DRILLING CO., INC.			LIC# 4033
DESCRIPTION		TOP OF STRATA	BOTTOM OF STRATA
SURFACE SOIL		0	5
TAN SAND		5	11
BLUE CLAY		11	21
BLUE CLAY & SHELLS		21	30
BLUE CLAY		30	59
SAND & GRAVEL		59	116
BLUE CLAY		116	135
WHITE SAND & GRAVEL		135	176
BLUE CLAY		176	185

OTHER COMMENTS: Geothermal Loops 3/4" x 180'. (5) Installed, 20' left out of ground.

RECEIVED
DEC 15 1999
WATER SUPPLY

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Michael T Hall License# 4034 Date 10/27/99
Signature of Well Driller In Charge